

Document 00 73 00 - Supplementary Conditions (WSU Design-Build)

State of Ohio Standard Requirements for Public Facility Construction

Certifications

These Supplementary Conditions amend and supplement the General Conditions and other provisions of the Contract Documents as indicated below. All provisions not amended remain in full force and effect. The terms in these Supplementary Conditions defined in the Contracting Definitions or the General Conditions shall have the meanings assigned to them in those documents.

These Supplementary Conditions are authorized, by the Ohio Facilities Construction Commission, for use on projects constructed by and for Wright State University ("University").

Contracting Authority

Wright State University
Engineering & Construction
3640 Colonel Glenn Highway
Dayton, Ohio 45435-0001
937.775.4140
<http://www.wright.edu>

Institutional Designee

Daniel Papay, P.E.
University Engineer

MODIFICATIONS TO GENERAL CONDITIONS

Insert Section 1.1.4 as follows:

1.1.4 This contractor and all subsequent subcontractors shall abide by the requirements of 41 CFR §§ 60-1.4(a), 60-300.5(a) and 60-741.5(a). These regulations prohibit discrimination against qualified individuals based on their status as protected veterans or individuals with disabilities, and prohibit discrimination against all individuals based on their race, color, religion, sex, or national origin. Moreover, these regulations require that covered prime contractors and subcontractors take affirmative action to employ and advance in employment individuals without regard to race, color, religion, sex, national origin, protected veteran status or disability.

Insert Section 1.10.3 as follows:

1.10.3 The DB shall provide the University with a list of contact persons, with telephone numbers, for 24-hour emergency contact.

Insert Sections 6.3.4.2 through 6.3.4.5 as follows:

6.3.4.2 The DB is responsible for contacting the University Engineering & Construction Department at construction@wright.edu to obtain a dig permit 72 hours in advance of any digging, excavation, trenching, drilling, driving posts or any other such work. The University's Excavation/Boring Permit shall be made a part of this document and can be obtained at <http://www.wright.edu>.

6.3.4.3 The DB shall physically locate underground utilities installed or exposed by the DB prior to backfilling. Physically locating means to measure each change in direction from two separate permanent objects and note the depth below grade on the As-Built Documents.

6.3.4.4 In conjunction with **Section 6.3.4.1**, the DB shall document the location of any existing or new utility or device uncovered or installed underground in accordance with **Section 6.3.4.3**. This information is to be timely provided to the Project Manager for incorporation into the University's utility drawings.

6.3.4.5 The DB shall backfill excavations with material specified by the AOR and approved in writing by the University. Surfaces (pavement, concrete, turf, etc.) shall be restored to like new conditions. Turf replacement shall be sod and not seed, unless otherwise approved by the University.

Insert Section 6.9.5.1.1 as follows:

- .1** Work performed in an area that must be kept in operation shall be protected with a sheeted bulkhead sufficient to keep out dust and dirt, and to isolate the area.

Insert Section 6.9.5.2.1 as follows:

- .1** The DB shall control fumes and dust to prevent any harmful or undesirable effects in the surrounding areas.

Insert Sections 6.9.6 through 6.9.10 as follows:

6.9.6 The DB, in coordination with the Project Manager, shall document the Site with a video recorder or other electronic means prior to the start of any Work on the Project. The video recording shall be made approximately 1 week prior to the start of construction. The purpose of the video recording will be to establish existing conditions before the Site is turned over to the DB. The video recording shall include, but is not limited to, lay-down/staging areas, condition of existing structures to remain, landscaping that is to remain or be restored subsequent to Project completion, any University property immediately adjacent to the Site, and ingress and egress routes across University property. The DB shall provide 1 copy of the video recording on a DVD-R disc to the Project Manager.

6.9.7 Temporary fencing shall be installed and maintained to protect the Site, including any lay-down areas, temporary offices, etc. The DB shall submit a fencing plan to the University prior to installation of any temporary fencing. The DB shall furnish and install chain link fencing, knuckled top and bottom, 6 feet high supported with minimum 1-5/8 inch line posts and 2-3/8 inch end/gate posts on 2 x 1 feet weighted bases a maximum of 10 feet on center. Mesh openings shall be a maximum of 2-3/8 inches. All fencing materials shall be galvanized. The University may require Knox locks be installed on entrance gates. Warning signs shall be posted on the fence 40 feet apart stating; "Construction Area-Keep Out" or similar verbiage approved in writing by the University.

6.9.8 The DB shall completely enclose the Site using temporary fencing under **Section 6.9.7**.

6.9.9 The DB shall ensure that the Site be secure from casual non-construction traffic (vehicular and pedestrian) from either entering in, or passing through, the Site and that the Site includes effective securing of equipment, storage of materials, and adequate lighting.

6.9.10 If the DB desires guard service, the DB may provide guard service at the DB's cost.

Replace Sections 6.12.4.1 and 6.12.4.2 with the following:

6.12.4.1 The DB shall notify the Project Manager 24 hours before the start of non-routine or non-recurring hot-work. Use of sources of fire, flame or sparks and flammable materials shall be kept to an absolute minimum. The DB shall take proper precautions to prevent fires when welding or while other fire-hazardous work is being performed. At the beginning of the Project, the DB shall inform the Project Manager of its intent to use blowtorches, welding apparatus, or similar exposed flame and sparking devices. Similar notice shall be given in regard to the use of flammable liquids, adhesives, and cleaners.

6.12.4.2 The DB shall furnish temporary fire extinguishers as required by Applicable Law (minimum of 1), which shall be within the immediate areas where work is being done at all times. The extinguishers shall be adequate and suitable for the class of fire likely to be caused by the DB's operations.

Insert Sections 6.12.4.3 through 6.12.4.5 as follows:

6.12.4.3 The DB shall implement and follow practices designed to minimize risk and avoid harmful exposure to chemicals, biological or radiological substances, and physical or mechanical hazards.

6.12.4.4 The DB shall use facilities and equipment in the prescribed manner to avoid injury and health damage to themselves, others, and the environment.

6.12.4.5 The DB shall submit a written lockout/tag out procedure based on OSHA requirements to the University for approval at the beginning of the Project. The DB shall use the approved procedure whenever a system is to be de-energized.

Insert Sections 6.12.5.2.1 and 6.12.5.2.2 as follows:

- .1 The licensed abatement contractor will make arrangements for the proper disposal of Hazardous Materials off-site according to Applicable Law and University regulations.
- .2 University trash receptacles, sanitary sewers, and storm drains shall not be used for the disposal of Hazardous Materials.

Insert Section 6.13.1.3 as follows:

6.13.1.3 The DB shall comply with requirements of Applicable Law during installation, use, and removal of temporary controls, facilities, and utilities.

Insert Section 6.13.3.7 as follows:

6.13.3.7 The requirements of this **Section 6.13.3** shall include testing or bacteriological analysis required for new domestic water piping per the American Water Works Standard C651. The DB shall be responsible for sampling and bacteriological analysis required in existing piping and/or buildings taken out of service related to this Project. Boil

advisory situations and the University's policy regarding water shutdowns can be found in the University's Community Water System Contingency Plan (copies available upon request).

Insert Sections 6.13.4.1.1 and 6.13.4.1.2 as follows:

- .1 A minimum of 10 foot-candles of night safety lighting covering the entire Site shall be provided for building construction (ANSI Standard 11.1-1973, Practice for Industrial Lighting).
- .2 Lighting removed by the DB during construction shall be replaced with adequate temporary lighting during construction as determined by the University.

Insert Section 6.14.4.2 as follows:

6.14.4.2 University trash receptacles, sanitary sewers, and storm drains shall not be used for the disposal of construction debris, waste materials, or rubbish.

Insert Section 6.14.5.2 as follows:

6.14.5.2 The DB shall maintain public streets and roads adjacent to property utilized for construction traffic clear, clean, and free from dirt and debris. Failure to clean public streets and roads will result in the University having it done at the expense of the DB in accordance with **Section 6.14.5.1**.

Insert Sections 6.15.6 through 6.15.11 and subordinate sections as follows:

6.15.6 Parking.

6.15.6.1 Main Campus. All parking on the University's Main Campus is restricted and controlled by the University's Parking & Transportation Department. Employees of contractors and subcontractors shall purchase parking permits from the Parking & Transportation Department and shall park cars in areas assigned to them. Contractors parking on University property will be charged the current rate to park, as space is available. Parking on streets or in restricted areas is prohibited. Violations will result in a citation or vehicle impoundment/ towing by a third party towing company. At the beginning of the Work, each contractor shall report to the Parking & Transportation Department the approximate number of parking permits which will be required for all employees, including employees of its subcontractors. On-site parking for all contractor personnel will not be permitted within construction limits.

6.15.6.2 All Other Campuses. Contractors performing Work on all other campuses shall coordinate with the Project Manager on matters of parking permits and designated areas.

6.15.7 The DB shall validate with the appropriate University, City, County, or State agency as to the status of road work impacting traffic flow on, to, and from, campus.

6.15.7.1 The DB shall not be permitted to use University streets for any purpose not previously approved by the Parking & Transportation Department. This includes, but is not limited to, trucks stopping on streets awaiting access to the Site. Should Site constraints be such that offloading of trucks from University streets is required, the DB shall provide a written request to the Parking & Transportation Department 5 days in advance of the date when the unloading is required. The DB shall pay for any traffic control occasioned by the street blockage. The DB shall also post signs three days in advance of any street blockage longer than 2 hours warning motorists of the date, time, and duration of the planned blockage.

6.15.8 The DB shall clean and restore storage areas to their original condition.

6.15.9 The University reserves the right to refuse to allow material it considers, in its sole discretion, to be a fire hazard to be stored on the University's property.

6.15.10 Gasoline and other flammable liquids shall be kept in approved safety cans at all times and shall not be stored inside University facilities.

6.15.11 The use of skid-steer loaders, track hoes, front loaders, back hoes, tractors, excavators, bulldozers, and similar equipment inside a structure is prohibited regardless of size, attachments, or type including, but not limited to, self-propelled, ride-on, or walk-behind.

Insert Section 6.16.3 as follows:

6.16.3 Interruptions to utility services shall be planned by the DB in coordination with the University, to provide the least inconvenience and downtime. A major utility shutdown requires a minimum of 4 weeks' notice from the DB. The DB shall provide a licensed and bonded electrician to operate all medium voltage electrical equipment and be present during the duration of the shutdown.

Insert Section 6.22.3.2 as follows:

6.22.3.2 If the Defective Work creates or contributes to a situation whereby the University is unable to occupy or use the space as intended, the DB shall begin to correct Defective Work within 24 hours of receiving notice.

Insert Section 6.22.5 as follows:

6.22.5 Failure to comply with this **Section 6.22** may cause the University to determine the DB non-responsive, which the University will use in determining the responsibility of the DB for award of future contracts.

Replace Section 7.9.2.1 with the following:

7.9.2.1 The DB shall maintain, and require its Subcontractors to maintain, complete and accurate business records in accordance with Generally Accepted Accounting Principles, at its principal place of business. If its principal place of business is not in Dayton, Ohio, the DB shall make records available, and shall require its Subcontractor to make records available, at the Site within 48 hours of a request for the records.

Insert Section 12.2.1.1 as follows:

12.2.1.1 The DB shall not advertise the fact that it has contracted with Wright State University, or make use of the University's name or other identifying marks or property, without the prior written consent of the University.

Insert Article 13 with associated Sections as follows in its entirety:

ARTICLE 13 - MISCELLANEOUS SUPPLEMENTARY CONDITIONS

13.1 Sexual Harassment

13.1.1 The University maintains an environment free from sexual harassment. DBs and Subcontractors are hereby notified that, in accordance with University policy, prompt corrective measures will be taken to stop sexual harassment whenever it occurs in accordance with **Section 6.11.2**.

13.2 False Fire Alarms

13.2.1 As liquidated damages, and not as a penalty, the DB acknowledges and agrees that the Contracting Authority shall be entitled to retain or recover from the DB \$300 or actual costs, whichever is greater, for each false fire alarm that is determined to be a result of negligence by the DB. This amount reflects the Contracting Authority's actual costs incurred in dealing with these false alarms, including, but not limited to, the costs of transportation, manpower, and loss of efficiency.

13.3 Safety and Health Rules

13.3.1 It is the policy of the University to provide a quality workplace environment for the learning experiences of teaching, education, work, and research which meets or exceeds Applicable Law for health and safety. The University's policy includes procedures relating to emissions by air, by liquid-carried wastes, by solid and hazardous waste disposal, or by sonic, radioactive, or electromagnetic radiation. The DB shall read and acknowledge by its signature that they have read and understand the policy. The University's Safety and Health Rules shall be made a part of this document and can be obtained at <http://www.wright.edu>. In addition the contractor shall follow and adhere to the applicable sections of the Wright State University Environmental Health and Safety Design and Construction Specifications/Requirements which are made a part of this document and can be obtained at <http://www.wright.edu>.

13.4 Impairment/Hot Work Permit

13.4.1 When construction operations require the impairment of the fire protection/alarm, fire suppression systems, shutdown, interruption or impairment of a utility system or require welding, cutting, burning or any open-flame/torch application, the DB shall follow the requirements of the University's Impairment/Hot Work Permit program. The University's Impairment/Hot Work Permit Program shall be made a part of this document in its entirety and can be obtained at <http://www.wright.edu>.

END OF DOCUMENT