

# RFQ Question and Answer List

## State of Ohio Standard Forms and Documents

---

Project Name Water Treatment Plant Upgrade Project Number DRC-110016  
Project Location Ross/Chillicothe Correctional Institution

---

Date posted: February 6, 2015

Date revised: N/A

Below are the questions that have been received to date for the RFQ of the above-referenced project:

1. The project name is **Water** Treatment Plant Upgrades – CCI, but the project description and the scope items for the project matrix relate to **Wastewater** Treatment Plant Upgrades. Can you please verify if the stated project name is correct, and if the project scope items 1-4 are correct.
  - A. The project name is correct.
  - B. There is a correction to the first item on the list of the project scope. Number 1 should say Experience in ~~sewer~~ **Water Treatment Plant** design/repair. Number 2-4 are correct.
2. Is this project more suited for an MEP/Plant Engineering Firm or a Civil Engineer?
  - A. MEP
3. Is the plant in question a surface water plant or a ground water plant? If it is a ground water plant, what processes are utilized at the plant?
  - A. The plant in question is ground water.
  - B. Greensand filtration, softening, chlorination and filtration are all used at the plant.