

RFQ Question and Answer List

State of Ohio Standard Forms and Documents

Project Name Student Services Renovation Project Number NSC-150001
Project Location Northwest State Community College

Date posted: May 28, 2015

Date revised: N/A

Below are the questions that have been received to date for the RFQ of the above-referenced project:

1. Are the MEP upgrades isolated to the "C" building only?
 - A. No, there will be some MEP work in adjacent buildings that will be required to facilitate the moving of the fitness and locker room areas.
2. Does the upgrade to the Fire protection/Alarm Systems extend throughout campus?
 - A. No, The Fire protection is for "C" building only. The Fire Alarm system will be upgraded only in "C" building, but will connect to our main panel in an adjacent building.
3. When can the site be viewed for a walk-through?
 - A. A walk-through is scheduled for Wed. 6/3/15 at 1 pm which is strongly recommended for potential A/E firms.