

RFQ Question and Answer List

State of Ohio Standard Forms and Documents

Project Name Convocation Center Structural Upgrades Project Number OHU-2016-121
Project Location 95 Richland Ave. Athens, Ohio

Date posted: 12/23/2015

Date revised: N/A

Below are the questions that have been received to date for the RFQ of the above-referenced project:

1. Will the original design drawings be available?
 - A. The selected consultant will have access to these documents.
2. Please clarify the expected role of the electrical engineer during the planning phase.
 - A. The proposed new scoreboard/video board installation will have electrical requirements, both to operate the electronics, and to provide a method for raising and lowering the unit for appropriate maintenance. The finished study must include an assessment of the existing power availability and suitability to support such an installation, and identification of upgrades to the building electrical infrastructure that may be required to support this installation.
3. The four existing wall mounted video and scoreboards were installed in 2003 or 2004..... Was a single center-suspended system considered at that time? If so, was the roof structure reviewed for that project, and will that study be shared with the consultant?
 - A. There is no information available regarding this question. The proposers should assume that no such study exists.