

RFQ Question and Answer List

State of Ohio Standard Forms and Documents

Project Name Toledo Deployment Processing & Fitness Center Project Number ADJ-180008
Project Location Toledo Air National Guard

Date posted: 5/2/2018
Date revised: 5/17/2018

Below are the questions that have been received to date for the RFQ of the above-referenced project:

1. Is SpecsIntact required for this project or traditional specifications?
 - A. Specifications and section numbers shall be consistent to CSI Master Format classification in accordance with UFC 1-300-02, United Facilities Guide Specifications (UFGS).
2. Is BIM required for this project or just 3D? If BIM is wanted, what level is desired?
 - A. Level 300 BIM is required.
3. Confirm the depth of Environmental Engineering needed for this project. Is a Phase I ESA required? Borings?
 - A. An Environmental Assessment has recently been completed. Awarded firm will be allowed to use the EA and does not need to perform a separate EA. Soil borings are required for building foundation but not for an environmental analysis.
4. What sporting activities will be performed in the fitness center?
 - A. Weight lifting (free weights and machines), cardio machines, aerobic fitness area, team sports if size permits