
WATER PRESSURE AND WATER FLOW POLICY

Subject: Consultant

Approval: Executive Staff

Code Section/Reference:

Owner: Planning

Policy Number: PL-04

Originally Issued: July 2008

Revised: December 2017

APPLIES TO

Regional Program Consultants and Assessing Consultants

Once a draft master facilities plan is created, but before it is finalized, the Regional Program Consultant and Commission Planning Manager need to ask the district if it has information available on water pressure and water flow. This information is needed to ensure the water pressure/flow is adequate to accommodate the new or renovated building, including the addition of a Fire Suppression System. If the district has an Architect/Engineer on board, they can assist the district in obtaining this information. If the district does not have an Architect/Engineer on board, the district may be able to obtain this information from the local fire department.