

RFQ Question and Answer List

State of Ohio Standard Forms and Documents

Project Name	<u>East - Renovate for Fluoro and ED X-Ray</u>	Project Number	<u>OSU-210346</u>
	<u>The Ohio</u>		
Project Location	<u>State University's East Hospital Campus at 181</u>		
	<u>Taylor Avenue, Columbus, Ohio 43202</u>		

Date posted: 8/5/2021
Date revised: 8/11/2021

Below are the questions that have been received to date for the RFQ of the above-referenced project:

1. If possible, could we please have a team of our architects and engineers come on site to review the project rooms?
 - A. We are only offering a site visit to the shortlisted firms.
2. Could we possibly find out what models of equipment are currently installed in the project rooms?
 - A. The equipment in East Tower C205D that is being replaced is a GE Precision Model # 2403929-2
 - B. East Main W270 the equipment is GE Proteus Model 2380179.
 - C. The CT scanner is a Siemens Definitions AS+128.
3. Is the existing CT setup for air-cooled or water-cooled Gantry, and will the new equipment be setup the same?
 - A. The existing and replacement are water cooled.